# **Energy performance certificate (EPC)**

12 Summershades Lane
Grasscroft
OLDHAM
OL4 4ED

Energy rating
C
Certificate
number:

Valid until:
21 December 2033

Certificate
9229-4200-0327-6003-0924
number:

Property type Detached house

**Total floor area** 202 square metres

### Rules on letting this property


Properties can be let if they have an energy rating from A to E.

You can read guidance for landlords on the regulations and exemptions (https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

### **Energy rating and score**

This property's energy rating is C. It has the potential to be C.

See how to improve this property's energy efficiency.



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

Breakdown of property's energy performance

# Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Cavity wall, filled cavity	Average
Roof	Pitched, 100 mm loft insulation	Average
Roof	Roof room(s), insulated	Good
Roof	Flat, insulated (assumed)	Average
Window	Fully double glazed	Good
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, room thermostat and TRVs	Good
Hot water	From main system	Good
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	Suspended, no insulation (assumed)	N/A
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	Room heaters, dual fuel (mineral and wood)	N/A

## Primary energy use

The primary energy use for this property per year is 194 kilowatt hours per square metre (kWh/m2).

### About primary energy use

### How this affects your energy bills

An average household would need to spend £3,515 per year on heating, hot water and lighting in this property. These costs usually make up the majority of your energy bills.

You could save £251 per year if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2023** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

# **Heating this property**

Estimated energy needed in this property is:

- · 24,239 kWh per year for heating
- 2,202 kWh per year for hot water

### Impact on the environment

This property's environmental impact rating is D. It has the potential to be  ${\sf C}.$ 

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

### Carbon emissions

# An average household produces 6 tonnes of CO2 This property produces 7.1 tonnes of CO2 This property's potential production 5.7 tonnes of CO2

These ratings are based on assumptions about average occupancy and energy use	. People living at the property may use different amounts of energy.

▶ <u>Do I need to follow these steps in order?</u>

# **Step 1: Floor insulation (suspended floor)**

Typical installation cost	£800 - £1,200
Typical yearly saving	£251
Potential rating after completing step 1	72 C

# Step 2: Solar photovoltaic panels, 2.5 kWp

Typical installation cost	£3,500 - £5,500
Typical yearly saving	£584
Potential rating after completing steps 1 and 2	78 C

# Help paying for energy improvements

You might be able to get a grant from the <u>Boiler Upgrade Scheme (https://www.gov.uk/apply-boiler-upgrade-scheme</u>). This will help you buy a more efficient, low carbon heating system for this property.

## More ways to save energy

Find ways to save energy in your home.

Who to contact about this certificate

# **Contacting the assessor**

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Muhammad Munir
Telephone	07594351050
Email	hello@epctoday.net

# Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited
Assessor's ID	QUID207734
Telephone	01225 667 570
Email	info@quidos.co.uk

### About this assessment

Assessor's declaration	No related party
Date of assessment	20 December 2023
Date of certificate	22 December 2023
Type of assessment	► RdSAP

### Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at <u>dluhc.digital-services@levellingup.gov.uk</u> or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

**Certificate number** 8891-6623-6100-4430-9092 (/energy-certificate/8891-6623-

6100-4430-9092)

Expired on 9 July 2019

Help (/help) Accessibility (/accessibility-statement) Cookies (/cookies)

Give feedback (https://forms.office.com/e/hUnC3Xq1T4) Service performance (/service-performance)

### **OGL**

All content is available under the <u>Open Government Licence v3.0 (https://www.nationalarchives.gov.uk/doc/opengovernment-licence/version/3/)</u>, except where otherwise stated



ht (https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-frameworl